





# New In-rack Design Criteria in NFPA 13 and FM Data Sheet 8-9

STEVEN WOLIN, VICE PRESIDENT, PRODUCT TECHNOLOGY & COMPLIANCE ANTONIO LUIS, TECHNICAL SERVICES MANAGER RELIABLE AUTOMATIC SPRINKLER CO., INC.

## Outline

### Background

- New Storage Criteria in NFPA 13: 2016 edition
- Testing of EC In-rack Sprinkler System

NFPA 13: 2019 edition

FM Data Sheet 8-9: July 2018 Interim Revision

Summary

# Background New Storage Criteria in NFPA 13: 2016 edition





### 2013 NFPA 13

No design criteria for Expanded Expanded Group A Plastics Stored in Racks



# New in NFPA 13: 2016 edition

Design criteria for Exposed Expanded Group A plastics stored in racks

- Max. Ceiling Height: 12m
- Max. Storage Height: 11m
- Min. Aisle Width: 2.4m
- Vertical barriers at max. 5.0m and 11.5m<sup>2</sup> intervals
- Sprinkler: K25.2 (K360) ESFR Intermediate Temperature
- Design Criteria: 12 sprinklers at 4.1 bar
- Basic water demand: 8 750 lpm



## FM Data Sheet 8-9

### Table 11

### **Uncartoned Expanded Plastics**

- Max. Ceiling Height: 12m
- Sprinkler: K25.2 (K360) QR Storage
- Design Criteria: 20 sprinklers at 5.2 bar
- Basic water demand: 16 420 lpm





Background Reliable Research on Extended Coverage In-rack Sprinkler System

## Why In-rack Sprinklers?

Tall Buildings
High Hazards
Water Savings



## Concepts

- 1. Virtual Floor
- 2. Extended Coverage In-rack Sprinkler System
  - N-RACK-EC<sup>®</sup>

## Virtual Floor



Extended Coverage **IRAS** N-RACK-EC®




## In-rack Sprinklers

STANDARD IN-RACK SPRINKLERS




EXTENDED COVERAGE IN-RACK SPRINKLERS K25.2 (K360) PENDENT





# Extended Coverage IRAS Tested Double-row Rack Layout



## Extended Coverage IRAS Test Exposed Expanded Group A Plastics

12m ceiling

11m storage

Ceiling level sprinkler system

K16.8 (K240) ESFR @ at 3.5 bar

In-rack sprinkler system

- K25.2 (K360) EC Pendent
  - 520 lpm per sprinkler
  - Intermediate temperature
- 1 level at 9.1m







## Extended Coverage IRAS Test Multiple-row Racks up to 4.7m Deep



## Extended Coverage IRAS Test Multiple-row Racks up to 4.7m Deep



# Extended Coverage IRAS Tested Multiple-row Rack Layout



## Extended Coverage IRAS Test Cartoned Unexpanded Group A Plastics

14.6m ceiling

13.1m storage

Ceiling

K25.2 (K360) EC Pendent @ 2.1bar


In-rack

- K25.2 (K360) EC Pendent
  - 520 lpm per sprinkler
  - Intermediate temperature
- 1 level at 30 ft




### Cartoned Unexpanded Group A Plastic Commodity






Images ©2013 UL LLC Used with permission



## NFPA 13: 2019 Edition

## 2019 NFPA 13



## Reorganized Storage Chapters

### Ch. 20

General Requirements for Storage

#### Ch. 21

 Protection of High Piled Storage Using CMDA Sprinklers

### Ch. 22

 CMSA Requirements for Storage Applications

### Ch. 23

ESFR Requirements for Storage Applications

### Ch. 24

Alternative Sprinkler System Designs

#### Ch. 25

 Protection of Rack Storage Using In-Rack Sprinklers

## 2019 NFPA 13 New Storage Protection Criteria

### 1. In-rack Sprinklers









**ESFR** 

### 2019 NFPA 13 New Storage Protection Criteria

### 2. In-rack Sprinklers



K25.2EC (K36) Pendent



# 1. ESFR In-rack Sprinklers

## ESFR In-Rack Max. Vertical Spacing of In-rack Levels





12m

- Class I IV Commodity
- Cartoned Unexpanded Plastic Commodity



9.1m

- Cartoned Expanded Plastic Commodity
- Uncartoned Plastic Commodity





Max. Vertical Spacing of In- rack Levels	Commodity	Min. K-factor	Min. Flow per In-rack Sprinkler
m		gpm/psi <sup>1/2</sup> (lpm/bar <sup>1/2</sup> )	lpm
9.1	Class I-IV Cartoned Unexpanded Plastics	14.0 (200)	250
	Cartoned Expanded Plastics	14.0 (200)	380
	<b>Uncartoned Plastics</b>	22.4 (320)	455
12	Class I-IV Cartoned Unexpanded Plastics	22.4 (320)	455






Rack Configuration	Number of Sprinklers in In-rack Hydraulic Design	
	Class I-IV Commodity and Cartoned Plastics	Uncartoned Plastics
Single-row racks up to 0.9m deep	4	4
Single-row racks up to 1.8m deep	5	5
Double- and Multiple-row racks	6	6 & 6

Not balanced with ceiling sprinkler system.

Treat highest in-rack sprinkler system as a "virtual floor" when selecting ceiling sprinkler system.


## ESFR In-rack: Single-row Racks






## ESFR In-rack: Double-row Racks








## ESFR In-rack: Multiple-row Racks







2. K25.2EC (K360)Pendent In-rack Sprinklers

# EC In-rack Vertical Spacing of In-rack Levels





9.1m

- Class I IV Commodity
- Cartoned Plastic Commodity



<u>6.1m</u>

Uncartoned Plastic Commodity

### EC In-rack Horizontal Barriers



Located at each in-rack level


Min. 10mm plywood or 0.7mm metal


Cover flue spaces

- 75mm max. gap permitted at uprights
- 75mm max. gap permitted at rack members, pipe drops, etc.

# EC In-rack Single-row Rack Layout









# EC In-rack Double-row Rack Layout





# EC In-rack Multiple-row Rack Layout





# EC In-rack Hydraulic Design



520 lpm per sprinkler

Single- and double-row racks

4 sprinklers

Multiple-row racks (up to 4.7m deep)

8 sprinklers (3 at each face and 2 in-between)

Not balanced with or added to ceiling sprinkler system demand

#### Installation Example 1

Scenario: Change of commodity in existing warehouse with 12m ceiling height

- Ceiling height: 12m
- Storage height: 10.7m
- Ceiling sprinkler system: K16.8 (K240) ESFR sprinklers
- Storage racks: Double-row 2.4m deep
- Old commodity: Cartoned Unexpanded Group A plastics
- New commodity: Exposed Expanded Group A plastics

#### Example 1: Existing 12m Building with Commodity Change

	Option 1	Option 2	Option 3	Ceiling Only
Ceiling sprinklers	Existing* K16.8 (K240) ESFR	Existing* K16.8 (K240) ESFR	Existing* K16.8 (K240) ESFR	New K25.2 (K360) ESFR
Ceiling sprinkler design criteria	Existing* 12 at 3.5bar	Existing* 12 at 3.5bar	Existing* 12 at 3.5bar	12 at 4.1bar
In-rack sprinklers	K8.0+ (K115+) QR	K22.4+ (K320+) ESFR	K25.2EC (K360EC) Pendent	None
In-rack sprinkler design criteria	8 at 230 lpm	10 at 450 lpm	4 at 520 lpm	None
No. In-rack Sprinklers per Rack Bay	10 (5 on 2 levels)	5	1	None
Basic sprinkler demand	5 400 lpm (existing)	5 400 lpm (existing)	5 400 lpm (existing)	8 750 lpm
Barriers	Horizontal	None	Horizontal	Vertical

<sup>\*</sup>Based on design criteria from FM Global Data Sheet 8-9

### Installation Example 2

Scenario: New Tall Storage Building

Ceiling height: 32m

Storage height: 29m

Storage racks: Double-row 2.4m deep

Commodity: Cartoned Unexpanded Group A plastics (CUP)



#### Example 2: New 32m Building with CUP Commodity

	Option 1	Option 2	Option 3a	Option 3b
Ceiling sprinklers	K25.2EC (K360EC)	K25.2EC (K360EC)	K25.2EC (K360EC)	K22.4 (K320) ESFR
Ceiling sprinkler design criteria	6 at 2.1bar	6 at 2.1bar	6 at 2.1bar	12 at 2.7bar
In-rack sprinklers	K8.0+ QR	K22.4+ (K320+) ESFR	K25.2EC (K360EC) Pendent	K25.2EC (K320EC) Pendent
In-rack sprinkler design criteria	8 at 230 lpm	6 at 450 lpm	4 at 520 lpm	4 at 520 lpm
No. In-rack Sprinklers per Rack Bay	35 (5 on 7 levels)	10 (5 on 2 levels)	3 (1 on 3 levels)	2 (1 on 2 levels)
Basic sprinkler demand	3 100 lp	3 100 lpm	3 100 lpm	6 400 lpm
Barriers	Horizontal	None	Horizontal	Horizontal

# FM Data Sheet 8-9 July 2018 Interim Revision

FM Global Property Loss Prevention Data Sheets

8-9

March 2010 Interim Revision July 2018 Page 1 01 87

### FM Data Sheet 8-9 July 2018 Interim Revision

#### 1.1 Changes

**July 2018.** Interim revision. a new Section 2.3.6.8 has been created to address the installation and design guidelines for protection scheme using quick-response K25.2EC (K360EC) pendent sprinklers as in-rack sprinklers in combination with horizontal barriers to protect open-frame rack storage of commodity hazards up to and including cartoned unexpanded plastics when the in-rack sprinkler protection was installed 30 ft (9.0 m) above floor level.

"... using quick-response K25.2EC (K360EC) pendent sprinklers as in-rack sprinklers ....""

# EC In-rack in FM Data Sheet 8-9 Commodities

Class I – IV

Cartoned nonexpanded group A plastic

Containers must be closed top



# EC In-rack in FM Data Sheet 8-9 Racks



Open frame racks

Single-, double- or multiplerow

Horizontal barriers at each in-rack level

- Extend across longitudinal flue
- Not required at transverse flues with uprights



# EC In-rack in FM Data Sheet 8-9 Horizontal Sprinkler Spacing

Linear: 2.1m to 2.5m

Area: 4.6m<sup>2</sup> to 6.3m<sup>2</sup>

Linear spacing may be 1.3m or less when area spacing is 1.6m<sup>2</sup> or less

Must be spaced at least 0.9m from rack uprights within single-row racks and double-row racks up to 2.4m wide

Exception: Where the max. linear spacing is 1.3m and max. area spacing is 1.6m<sup>2</sup>

# EC In-rack in FM Data Sheet 8-9 Rows of Sprinklers per Level



Rack Type	No. Rows of Sprinklers per In-rack Level	
Single-row	1	
Double-row up to 2.7m deep	1	
Double-row more than 2.7m deep	2	
Multiple-row	Use horizontal spacing rules and provide sprinklers within 450mm of each rack face	

# EC In-rack in FM Data Sheet 8-9 Vertical Spacing



Max. Vertical Distance between in-rack sprinklers: 9.0m

Max. distance from deflector to horizontal barrier: 175mm

Min. clearance from storage to deflector: 225mm

# EC In-rack in FM Data Sheet 8-9 Design Criteria: 605 lpm per sprinkler



Rack type	Rack depth	Aisle width	No. of IRAS in Design
Single-row	Up to 1.8m	Up to 1.2m	6 total; 3 in most remote rack and 3 in nearest adjacent rack
		Over 1.2m	3 in most remote rack
Double-row	Up to 9.7m	Up to 1.2m	8 total; 4 in most remote rack and 4 in nearest adjacent rack
		Over 1.2m	4 in most remote rack
	Over 9.7m	Any	8 total; 4 on each rack face in most remote rack
Multiple-row	Any	Any	8 total; 4 along the rack face and the nearest 4 sprinklers in the most remote rack

### Ceiling Sprinkler Design Criteria The "Virtual Floor"



Consider the top level of in-rack sprinklers as a floor when selecting the ceiling sprinkler system design criteria.

# EC In-rack in FM Data Sheet 8-9 Water Demand



Hose stream allowance: 950 lpm

Water supply duration: 60 minutes

In-rack sprinkler system not balanced with or added to ceiling level sprinkler demand when overhang of commodity beyond horizontal barrier is max. 75mm.

# Summary

#### 2019 NFPA 13

Anticipated publication September 2018

New in-rack design criteria using ESFR sprinklers or K25.2EC (K360EC) Pendent sprinklers

#### FM Data Sheet 8-9 July 2018 Revision

New in-rack design criteria for K25.2EC (K360EC) QR Pendent Sprinklers

# Designing "Independent" In-rack Sprinkler Systems

USE THE "VIRTUAL FLOOR"

FOR EXTENDED COVERAGE AT THE CEILING





Thanks for your attention!!!!